


**Structural Engineering Analysis – 90 MPH Wind Velocity
 For 16’ x 16’ *HB&G Building Products, Inc.* Pergola with 10” columns**

Analysis was performed based on ASCE 7-10 Code, for the 16’ x 16’ *HB&G Building Products, Inc.* Pergola with 10” round or square columns. The analyses were performed with one (1) anchor per column base plate and the design reflects ASCE 7-10 wind load rating of 90 MPH with the following assumptions:


- 1) (1) Anchor – Wedge type stainless steel 5/8” diameter with 4” embedment (True Bolt WW-5860, Kwik Bolt 3 – SS 5/8 (4) or equivalent).
- 2) (1) 5/8” threaded rod (std. Low Carbon Steel).
- 3) (16) Flat Washer, Large OD, 18-8 Stainless Steel washer at each (1/4” -14 x 2 1/2”) screw location; qty: 4 per column; 16 washers in total.
- 4) Threaded rod extends through column and bolted to aluminum top plate.

Result: The configuration characterized herein for this structure can resist 90 MPH wind load as per ASCE 7-10 Code with minimum footing size: 12” x 12” x 30” deep or equivalent, 3000 psi concrete.



Respectfully Submitted by:

MW Engineering, Inc.



8/29/2014

Mark E. Weber, PE 53895
 Florida Registered Professional Engineer

